CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7165-0082:101 Page 1 of 1

CATEGORY: Control Unit (Non-High Rise)

LISTEE: Rauland-Borg, 3450 W. Oakton St., Skokie, IL 60076

Contact: Daryl Miceli (708) 679-0900

DESIGN: Model "FIREPLEX FA3001" fire alarm control unit. Power-limited, automatic or manual, coded or

noncoded; local service; area, zone or all-call annunciation. Conventional Style A initiating circuit and Style Y indicating circuit. *System also has optional Class B combination initiating

and indicating circuits (Refer to "Approval" section for details). System components:

FA 3001 Control Unit

FA 3120/3125 Station Supervisory Panel

FAX 60/120/250 Audio Amplifier 1343/44/45/46 End-of-Line Resistor

DCM Display Command Module
IOM Input/output Module
AMM Audio Monitor Module
CPU Central Processor
FA3010 Power Supply/Battery Charger

La Marche A12B3 Power Supply/Battery Charger

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, UL and SFM label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating

devices. System must be configured for automatic all call annunciation to satisfy local service (all

buildings/zones/floors).

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturer's

Installation Manual for details.

Optional combination initiating and indicating circuit can be used only if approved by the authority

having jurisdiction. Please consult the authority having jurisdiction (AHJ) prior to installation.

*Corrected 03-02-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: MARCH 13, 2001 Listing Expires June 30, 2002

A uthorized By: **BEN HO**, Supervising Deputy Program Manager